


EXAMPLE - MULTIPLE ZONE DESIGN.



300 m² / 3 m CEILING
LECTURE HALL ∴ 150 P / 100 m²
∴ 450 PEOPLE.
ACH = 4 TO 10 ∴ 8 ACH
 $Q_{SA} = \frac{(300 \times 3)(8)}{3.6} = 2000 \text{ } \dot{V}_s$
 $Q_{OA} = (3.8 \times 450) + (0.3 \times 300)$
 $= 1800 \dot{V}_s$
 $\% OA_A = 1800 / 2000 = 90 \%$

100 m² / 3 m CEILING
CLASSROOM 35 P / 100 m²
∴ 35 P
ACH = 4 TO 10 ∴ 8 ACH.
 $Q_{SA} = \frac{(100 \times 3)(8)}{3.6} = 667 \dot{V}_s$
 $Q_{OA} = (5 \times 35) + (0.6 \times 100)$
 $= 235 \dot{V}_s$
 $\% OA_B = 235 / 667 = 35 \%$

THIS WILL NOT WORK AS $\% OA_A \neq \% OA_B$
WHAT TO DO?

SOLUTION 1: INCREASE Q_{SA} OF ZONE (A)

TO MAKE $\% OA_A = \% OA_B = 35\% \dots Q_{SA} = \frac{1800}{0.35} = 5143 \dot{V}_s$.
OR $ACH_A = 20.6$! WOW. BIG!

SOLUTION 2: INCREASE Q_{OA} OF ZONE (B)

TO MAKE $\% OA_A = \% OA_B = 90\% \dots Q_{OA} = 667 \times 0.9 = 600.3 \dot{V}_s$
THAT RAISES TO TOTAL OA FROM $1800 + 235 = 2035 \dot{V}_s$
TO $\dots 1800 + 600 = 2400 \dot{V}_s$.
THAT'S A 18% INCREASE IN OA ($2400 / 2035 = 1.18$)

SOLUTION 3: DO BOTH BUT IN MODERATION.

(A) : $ACH = 12 \rightarrow Q_{SA} = 3000 \dot{V}_s \rightarrow \% OA = 1800 / 3000 = 60\%$

(B) : $Q_{OA} = 667 \times 0.6 = 400.2 \dot{V}_s$

THAT RAISES THE SA BY $\dots \frac{(3000 + 667)}{(2000 + 667)} = 37\%$

ALSO RAISES THE OA BY $\dots \frac{(1800 + 400.2)}{(1800 + 235)} = 8\%$ ①

EXAMPLE - CHECKING YOUR DIFFUSER LAYOUT




Table 5: Air diffusion performance index (ADPI) selection guide

Terminal Device	Room Load W/m ²	T _{0.25} /L for Max. ADPI	Max. ADPI	ADPI Greater Than	Range of T _{0.25} /L
High Sidewall Grilles	250	1.8	68	-	-
	190	1.8	72	70	1.5 to 2.2
	125	1.6	78	70	1.2 to 2.3
	65	1.5	85	80	1.0 to 1.9
	< 30	1.4	90	80	0.7 to 2.1
Circular Ceiling Diffusers*	250	0.8	76	70	0.7 to 1.3
	190	0.8	83	80	0.7 to 1.2
	125	0.8	88	80	0.5 to 1.5
	65	0.8	93	80	0.4 to 1.7
	< 30	0.8	99	80	0.4 to 1.7
Sill Grille Straight Vanes	250	1.7	61	60	1.5 to 1.7
	190	1.7	72	70	1.4 to 1.7
	125	1.3	86	80	1.2 to 1.8
	65	0.9	95	90	0.8 to 1.3
	250	0.7	94	90	0.6 to 1.5
Sill Grille Spread Vanes	190	0.7	94	80	0.6 to 1.7
	125	0.7	94	-	-
	65	0.7	94	-	-
Ceiling Slot Diffusers (for T _{0.25} /L)	250	0.3	85	80	0.3 to 0.7
	190	0.3	88	80	0.3 to 0.8
	125	0.3	91	80	0.3 to 1.1
	65	0.3	92	80	0.3 to 1.5
Light Troffer Diffusers	190	2.5	86	80	< 3.8
	125	1.0	92	90	< 3.0
	65	1.0	95	90	< 4.5
Perforated & Louvered Ceiling Diffusers	35 to 160	2.0	96	90	1.4 to 2.7
	35 to 160	2.0	96	80	1.0 to 3.4

*Includes square cone diffusers and square plaque diffusers

L = CHARACTERISTIC LENGTH

$$L_{A1} = 7.5 + 1.5 = 9 \text{ m} = 29.5 \text{ FEET}$$

$$L_{A2} = 2.5 + 1.5 = 4 \text{ m} = 13.1 \text{ FEET}$$

$$L_B = 5 + 1.5 \text{ m} = 6.5 \text{ m} = 21.3 \text{ FT.}$$

FOR CIRCULAR CEILING DIFFUSERS
GOAL THROW

$$\left[\frac{T_{0.25}}{L} \right] = 0.8 \quad \boxed{\text{E.H. PRICE, ADPI TABLE 5}}$$

$$T_{0.25A1} = 9 \times 0.8 = 7.2 \text{ m} = 23.6 \text{ FT}$$

$$T_{0.25A2} = 4 \times 0.8 = 3.2 \text{ m} = 10.5 \text{ FT}$$

$$T_{0.25B} = 6.5 \times 0.8 = 5.2 \text{ m} = 17.1 \text{ FT}$$

$$Q_{\text{DIFFUSER A}} = 3000 \text{ l/s} \div 4 = 750 \text{ l/s} = 1590 \text{ CFM}$$

$$Q_{\text{DIFFUSER B}} = 667 \text{ l/s} = 1414 \text{ CFM}$$

DIFFUSER SELECTION

E.H. PRICE, SPD, 24x24, SIZE 15

ACTUAL (LISTED) THROW: $T_{0.25A} \approx 21 \text{ FT}$, $T_{0.25B} \approx 19.5 \text{ FT}$

WILL THIS DIFFUSER WORK?

ACCEPTABLE RANGE OF $T_{0.25}/L = 0.7$ TO 1.2

OUR OPERATING $T_{0.25}/L$ 'S ARE:

A1: ACTUAL $T_{0.25}/L = 21/29.5 = 0.71$ OK

A2: ACTUAL $T_{0.25}/L = 21/13.1 = 1.6$ NOT OK

B: ACTUAL $T_{0.25}/L = 17.1/24.6 = 0.7$ OK (CLOSE BUT OK.)

$$\boxed{\text{E.H. PRICE, ADPI TABLE 5, ROOM LOAD} = 190 \text{ W/m}^2}$$

②